


**FORM E**

Form of Report to be made to the Competent Authority by Inspecting Authorities or Officers appointed Under Section 238 of the Madras Public Building (Licensing Act 1965 Madras Act 13 of referred to in rule 7 of the Madras Public Building (Licensing) Rule 1966.

1. Name and designation if inspecting authority or office appointed or having jurisdiction under any other Act or Law	N.Raghuraman ,ME.(Struct),Msc.,(REV),FIV., MIE.,MISTE,MIIT(Arb)S/o.(Late)S. NarayanaRao Residing at 17-1,First Floor, MKP Colony, Main Street, Ganapathy, Coimbatore
2. Location of the building inspected D.No, Street No, Name of the Place i.e Municipal Corporation/Municipality /Panchayat/ Panchayat,Union /Township/Cantonment	M/s.VEDANTA ACADEMY Contact:9894080089 S.F.No:19/1B1,1B2,2B1,2B2,3B,4A,20/1,20/2A Unjapalayam , Kuppandampalayam village & Panchayat , Avanas Taluk, Tirupur District-641654.
3. Date of Inspection	07.05.2020
4. Propose for which the building is used	School Building
5. Nature of defects noticed	Nil(Maintained Properly)
6. Suggestion for rectifying defects	Does not arise
7. If in a dangerous condition Immediate action recommended be taken	No (Good Condition)

Date: 12.05.2020

Place: Coimbatore



NR RAGHURAM & CO
 1271, AVANASI TALUK, TIRUPUR DISTRICT, COIMBATORE
 Registered Telugu No: 0719-2014, Andhra Valuer No: P-1642
 District Civil Eng. No: 2456-14/256-5, Technical Assistant-1-691-682
 Licensed Building Surveyor-12/5/91, Class-11 First Engineer No: 27013
 "Narayan Kumar" 17-1, MKP Colony, Main Street,
 Ganapathy, Coimbatore-641 005
 Phone / Cell : 3422 - 252651, 97277 10209
 Email / Website : nr@nr-raghu.com, www.nr-raghu.com
 Website : 02201 14444, 02201 14440

Signature of inspecting Authority /Officer

Appointed or Having Jurisdiction

STATEMENT ACCOMPANY

FORM - A

ORIGINAL

1.	Name of the Institution	:	M/s.VEDANTA ACADEMY Contact:9894080089																																															
2.	Door No. of the building Location (Street No., Ward No., Name of Place, I.e. Corporation, Municipality/ Panchayat Union/Panchayat/ Township/Cantonment)	:	S.F.No:19/1B1,1B2,2B1,2B2,3B,4A,20/1,20/2A Unjapalayam , Kuppindampalayam village & Panchayat , AvanasiTaluk, Tirupur District-641654.																																															
3.	Year of Construction	:	2008																																															
4.	Approximate cost of Construction As per Current rates	:	Rs. 1,89,47,131/- : Say Rs. 1,89,47,000/-																																															
5.	Total Built up Area of the Building :																																																	
	<table border="1"> <thead> <tr> <th rowspan="2">S.No</th> <th rowspan="2">AREA DETAILS</th> <th colspan="2">Sq.ft</th> </tr> <tr> <th>Block A</th> <th>Block B</th> </tr> </thead> <tbody> <tr> <td rowspan="4">1.</td> <td>Main Building</td> <td></td> <td></td> </tr> <tr> <td>Ground Floor</td> <td>4323.38</td> <td>5900.87</td> </tr> <tr> <td>First Floor</td> <td>4323.38</td> <td></td> </tr> <tr> <td>Second Floor</td> <td>4323.38</td> <td></td> </tr> <tr> <td></td> <td>Toilet Building</td> <td></td> <td></td> </tr> <tr> <td></td> <td>Boys Toilet</td> <td>476.63</td> <td></td> </tr> <tr> <td></td> <td>Girls Toilet</td> <td>511.50</td> <td></td> </tr> <tr> <td></td> <td>Indoor Stadium</td> <td>2301.75</td> <td></td> </tr> <tr> <td></td> <td>Prayer Hall & Staff Room</td> <td>2185.88</td> <td></td> </tr> <tr> <td></td> <td>Canteen</td> <td>347.88</td> <td></td> </tr> <tr> <td></td> <td>Total</td> <td>18793.78</td> <td>5900.87</td> </tr> </tbody> </table>			S.No	AREA DETAILS	Sq.ft		Block A	Block B	1.	Main Building			Ground Floor	4323.38	5900.87	First Floor	4323.38		Second Floor	4323.38			Toilet Building				Boys Toilet	476.63			Girls Toilet	511.50			Indoor Stadium	2301.75			Prayer Hall & Staff Room	2185.88			Canteen	347.88			Total	18793.78	5900.87
S.No	AREA DETAILS	Sq.ft																																																
		Block A	Block B																																															
1.	Main Building																																																	
	Ground Floor	4323.38	5900.87																																															
	First Floor	4323.38																																																
	Second Floor	4323.38																																																
	Toilet Building																																																	
	Boys Toilet	476.63																																																
	Girls Toilet	511.50																																																
	Indoor Stadium	2301.75																																																
	Prayer Hall & Staff Room	2185.88																																																
	Canteen	347.88																																																
	Total	18793.78	5900.87																																															
6.	Purpose for which the building is being used or Proposed to be used	:	Educational Purpose																																															
7.	Details of Construction of the Building (particulars of the Foundation, soil, Specification of the various parts under)	:																																																
	a. Foundation	:	Brick Workin C.M Mix, RCC Column Footing																																															
	b. Basement	:	Brick Work in CM 1:5																																															
	c. Super Structure	:	Brick Work in CM 1:5																																															
	d. Floor	:	Plain Cement ConcreteFlooring																																															



FORM - C

(Form of Certificate of structural soundness under sub-section (4) of Section 4 of the Tamilnadu Public Building (Licencing) Act, 1965 (Tamilnadu Act 1965) referred to in rule 4 of the Tamilnadu Public Building (Licencing) Rules 1966).

Location of the building, Door No., Street and Name of the place	Age of the building	Total Value of the Building at the Current Rate	Short description of structure - steel-RCC framed of load bearing masonry	Purpose for which the building is certified for use	The Period for which the building will be structurally soundless	No. of persons to be accommodated	Remarks
M/s.VEDANTA ACADEMY Contact: 9894080089 S.F.No:19/1B1,1B 2,2B1,2B2,3B,4A, 20/1,20/2A Unjapalayam , Kuppandampalayam village & Panchayat , Avanasitaluk, Tirupur District 641654.	12 Yrs	Rs. 1,89,47,000/-	RCC Framed Structure	Educational Purpose	3 Years 01.06.2020 to 31.05.2023	900Nos (Students + Teaching + Non-Teaching Staffs)	Nil

Place: Coimbatore

Date: 12.05.2020



(Form of Certificate of structural soundness under sub-section (4) of Section 4 of the Tamil Nadu Public Building (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 4 of the Tamil Nadu Public Building (Licensing) Rules 1966).

1. FOUNDATION:

- | | | |
|--|---|-------------------------|
| a) Depth below ground level | : | 8"0" Below Ground Level |
| b) Nature of soil met with at Foundation level | : | Hard Gravel |
| c) Pressure at foundation | : | 4.10 T/m ² |
| d) Probable safe bearing capacity of | : | 33 T/m ² |

The soil met with at foundation


2. SUPER STRUCTURE:

- | | | |
|--|---|--|
| a) Maximum stress in the most critical Section of masonry and concrete | : | Masonry-1.5N/mm ²
Concrete-12N/mm |
| b) Nature of masonry and concrete and its Safe permissible stress | : | Brick Masonry-5N/mm ²
Concrete- 15 N/mm ² |

The structural soundness of the building has been verified by me with reference to I.S.I Loading standards 875 (Latest Version) and other relevant Indian Standard code of practice and I declare that the building is structurally sound to be used as School Building for the purpose Noted in the statement. A licence may be granted for the period from 01.06.2020 to 31.05.2023.

Place: Coimbatore

Date: 12.05.2020 ✓



NR RAGHURAM & CO
 AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & ARCHITECTS
N. RAGHURAM, MMS, MCE (P) and **THEYALAKSHI, BSC, MCA, MIBMS**
 Registered No. No:10013-2014, Approval Value No: P1040
 Chartered Civil Engineer, No: 142250-5, Technical Job from No: 021-02
 Licensed Building Surveyor and Scribe, Class 14 Town Engineer No: 20013
 "Vakase Street" 37-1, 1st Floor, Main Street,
 Guindy, Coimbatore - 641 005
 Phone / Cell : 8472-203309, 09872-15009
 Email / Website : nr12@nr-raghuram.com / www.nr-raghuram.com
 Website : 94428-12488, 98428-15009

Ref No: NR/RV/2020/001

NR RAGHURAM & CO ORIGINAL

AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & VALUERS

Proprietor : **Mr. N.RAGHURAMAN**, MRICS, ME.(Struct), MSc (REV), MSc (P&M), FIV, AMIE, MISSE, MISTE, MIIT (Arb)



International Valuers, Registered Valuers, (Wealth Tax Valuers),
Bank Approved Valuers, Chartered Civil Engineers, Class 1A Panel Engineers,
Consulting Civil Engineers, L B S (Grade II), Technical Arbitrators



DECLARATION

I, **Mr. N.RAGHURAMAN**, ME.(Struct), Msc.,(REV), FIV., AMIE., MISTE, MIIT(Arb)

S/o. (Late) S.Narayana Rao, Residing at 17-1, First Floor, MKP Colony, Main Street, Ganapathy, Coimbatore, do hereby I possess the qualification and experience specified in the Table Rule II of the Madras Public Building (Licensing) rules 1966 for issuing the certificates of structural soundness of the building covered by the certificate.

Place: Coimbatore.

Date: 12.05.2020

- | | | |
|---------------------------|---|---|
| 1. Name and Address | : | N.Raghuraman ME, FIV, AMIE, MISTE
17-1, First Floor, MKP Colony
Main Street, Ganapathy, Coimbatore. |
| 2. Engineer Qualification | : | ME.(Struct), Msc.,(REV), FIV., MIE.,
MISTE, MIIT(Arb) |
| 3. Experience | : | 23 Years |

N. Raghuraman
NR RAGHURAM & CO
 AN ISO 9001:2015 CERTIFIED COMPANY
M. RAGHURAMAN, MRICS, ME.(Struct), MSc (REV), MSc (P&M), FIV, AMIE, MISSE, MISTE, MIIT(Arb)
 Registered Valuer No: 12019/2014, Approved Valuer No: F18103
 Chartered Civil Engineer, No: 147228-C, Technical Arbitrator No: 305-032
 Licensed Building Surveyor No: 25 No. 1, Class-1A Panel Engineer No: A2019
 "Narasarao Niwas" 17-1, MKP Colony, Main Street,
 Ganapathy, Coimbatore - 641 006
 Phone / Cell : 9422-253891, 97877-15858
 Email / Website : nr_raghuram2000@gmail.com / www.nr_raghuram.org
 REGD. OFFICE : 9422-15858, 97877-15858

Off : "Narasarao Niwas" D.No. 17-1, 1st Floor, MKP Colony, Main Street, Ganapathy, Coimbatore - 641 006.

Office Ph : 0422 253891, 4356957. Cell : 97877 15858, 90430 15859,

E.mail : n_raghuram2000@yahoo.com, nr_raghuram@gmail.com Website : www.nr_raghuram.org

Cell : 98438 - 15858



PROCEEDINGS OF THE DISTRICT COLLECTOR, TIRUPPUR
PRESENT : Dr.K.VIJAYAKARTHIKEYAN, I.A.S.,

Ref. No. 272/2017/E1

Dated :17.01.2020

Sub : Tamil Nadu Public Building Licensing Act 1965 -
Inclusion of the name of Thiru.N.Raguraman in the Panel
of Private Practising Engineers in CLASS IA Category in
Tiruppur District - Approval of the Board of Engineers -
Order issued - Regarding.

Ref : 1) Superintending Engineer, PWD, Buildings
(C&M) Circle, Coimbatore Lr No DB/DO.1/F.1142/5M/
2018, dated 22.01.2019.
2) Engineer-In-Chief WRD & Chief Engineer (General)
PWD, Chennai, Letter No.AEE/T1/AE-2/32120/2018,
dated 21.11.2019.

ORDER:-

The Engineer-In-Chief WRD & Chief Engineer (GI) PWD, Chennai,
in the reference 2nd cited has accorded approval for inclusion of the name of
Thiru.N.Raguraman (D.O.B.17.05.1972) residing at Narayan Niwas, D.No.17-1,
1st floor, MKP Colony, Main Street, Ganapathy, Coimbatore - 641 006 in the
panel of Private Practising Engineers in Tiruppur District under CLASS IA
Category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per
G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department,
dated 17.02.2011) in Tiruppur District.

Accordingly, the name of Thiru.N.Raguraman is hereby included in
the panel of Private Practising Engineers under CLASS IA, the buildings cost
which exceeds Rs.50.00 Lakhs as per G.O.Ms.No.43, Municipal Administration
& Water Supply (MA4) Department, dated 17.02.2011 in Tiruppur District and
included his name against Sl.No.02/2020 in the Register of Panel of Private
Engineers in CLASS IA maintained in Tiruppur District.

Sd/-K.Vijayakarthykeyan,
District Collector,
Tiruppur.

To

Thiru.N.Raguraman,
Narayan Niwas,
D.No.17-1, 1st floor,
MKP Colony, Main Street,
Ganapathy, Coimbatore - 641 006.

Copy to

1. Superintending Engineer, PWD Buildings (C & M) Coimbatore.
2. Engineer-In-Chief WRD & Chief Engineer (General) PWD, Chennai.
3. Stock File

// True copy // By Order //

For District Collector

RAIN WATER HARVESTING REPORT

This is to certify that **M/s. VEDANTA ACADEMY**, Contact: 9894080089.
S.F.No: 19/1B1, 1B2, 2B1, 2B2, 3B, 4A, 20/1, 20/2A Unjapalayam, Kuppandampalayam village &
Panchayat, Avanasi Taluk, Tirupur District 641654.

Where rain Water harvesting report is listed below.

The Rain Water which is collected from roof top is taken safely to the ground pits
through PVC pipes. Each block contains five percolation pits of size 1'0"x1'0"x10'0"

The water is taken to percolation pits by 2" PVC pipes.

Percolation Pit

Percolation pit consists of size 1'0"x1'0"x10'0" which is filled by broken brick jelly and top layer is
filled by river sand.

The water percolates through the percolation pits gets filtered by river sand and brick jelly and the water
enter into earth and increase the water level.

Place: Coimbatore

Date: 12.05.2020



NR RAGHURAM & CO
AN ISO 9001:2015 CERTIFIED COMPANY ENGINEERS & ARCHITECTS

N. RAGHURAM, MNS, MS (Struc), MS (Civil), MS (ME), MS (ESTIMATION)
Registered Member No: 0713-2014, Approved Valuer No: P50430
Chartered Civil Engineer, Arch-147704-S, Technical Architect No: 631-082
Licensed Estimator Category No: 2902-1, Civil-14 Field Engineer No: 3/2013
"Meyyanthi Murug" 17-1, MGOP Colony, Main Street,
Ganapathy, Coimbatore - 641 036
Phone / Cell : 9442-263301, 97377 15858
Email / Website : nrraghu@rediffmail.com / www.nr-raghu.com
Mobile : 90420 16445, 98940 80089